

DATE: October 10, 2018

SUBJECT: **Addendum No. 5**
Union County Public Schools
Walkway Canopy Projects

FROM: Ramsay Burgin Smith Architects, Inc.
225 North Main Street - Suite 501
Salisbury, NC 28144

General: Information contained in this Addendum and changes directed in Drawings and/or Project Manual supersede said Documents and become part of the Contract. Receipt of this addendum must be acknowledged on the bid Form of Proposal.

All Contractors, General and subcontractors should review all Addenda Items for work that pertains to or affects their trade.

ARCHITECTURAL SPECIFICATIONS:

ITEM #01: Reference Section 10730 – ALUMINUM WALKWAY COVERS:

Extruded aluminum pans shall be minimum 14 gauge (0.06 in.), with 2-inch minimum depth. Provide pans with gauge/depth as required to carry specified loads.

ARCHITECTURAL DRAWINGS:

ITEM #02: Reference A8.3-11 CANOPY DETAIL:

A direct embedment footing design engineered by the canopy system manufacturer may be used at Parkwood High School in lieu of base plate design detailed on A8.3, provided that elevations shown on drawings for canopy heights are maintained. Shop drawings for canopies shall include base/post connections and footings sized and detailed by a NC professional engineer (sealed) for this application and location. Reference specific loading requirements for infrastructure on A8.3.

END OF ADDENDUM No. 5